


LO-PRO III

Low Profile Air Stripper and Geotech Environmental Control Module

Installation and Operation Manual



NEED HELP?



SCAN OR CLICK HERE
TO CONTACT US

Table of Contents

Section 1: System Description	3
Function and Theory	3
The LO-PRO III(S) System	4
System Components.....	7
Optional Components	9
Section 2: System Installation	11
Section 3: System Operation	18
Section 4: System Maintenance.....	21
Section 5: System Troubleshooting	29
Section 6: System Specifications	36
GECM Specifications	39
Transfer Pump Specifications	42
Section 7: System Schematic	43
Section 8: Replacement Parts and Accessories.....	44
Appendix A – GECM Logic Statement.....	46
Appendix B – GECM Installation.....	56
Appendix C – Decontamination Procedures.....	59
The Warranty.....	65

DOCUMENTATION CONVENTIONS

This document uses the following conventions to present information:



WARNING

An exclamation point icon indicates a **WARNING** of a situation or condition that could lead to personal injury or death. You should not proceed until you read and thoroughly understand the **WARNING** message.



CAUTION

A raised hand icon indicates **CAUTION** information that relates to a situation or condition that could lead to equipment malfunction or damage. You should not proceed until you read and thoroughly understand the **CAUTION** message.



NOTE

A note icon indicates **NOTE** information. Notes provide additional or supplementary information about an activity or concept.

Section 1: System Description

Function and Theory

The Low Profile Air Stripper III (LO-PRO III) is a cost-effective, modular system designed for the efficient removal of volatile organic compounds from groundwater. The LO-PRO III is compact, unobtrusive, and can be discreetly integrated into any site landscape. The modular construction of the system makes it easily adaptable to changing conditions and requirements. By adding or subtracting aeration trays, the LO-PRO III can be fine-tuned for different influent concentrations and removal efficiencies. Figure 1-1 shows a standard three-tray system. Figure 1-2 is an example of a LO-PRO III system with optional equipment components.




Figure 1-1: Example of a LO-PRO III with three trays.

The standard LO-PRO III system consists of a 187 gallon (708 L) sump with integral floor mounts, three to five aeration trays with integral gaskets and latches, a lid with mist eliminator, a 10HP blower, and a static pressure gauge. Each aeration tray consists of an alternating, stainless steel bubble plate with attached downcomer for funneling water. The sump, trays, and lid are constructed of low density polyethylene. PVC pipe is used for all external plumbing and fittings. Refer to *Section 8: Replacement Parts and Accessories* for a list of parts and optional equipment. See *Section 4: System Maintenance* for more information on unit maintenance and tray orientation.



Sump capacity is based approximately on the dimensions of the sump to the height of the water HI OVERRIDE switch (blue float) of the sump probe. When actuated, the HI OVERRIDE switch will shut off the influent water pump, preventing the sump from over-flowing. During normal operation, the HI LEVEL switch (orange float) will turn on the effluent transfer pump and empty the sump (of approximately 75 gallons or 284 L) or until the LO LEVEL switch on the probe is reached. See also the probe diagram in Figure 1-5.




Figure 1-2: LO-PRO III system deployed with optional GECM, Transfer Pump, and Water Table Depression Pump

The LO-PRO III(S) System

The LO-PRO III(S) is a freestanding, integrated system designed to operate under the rigorous demands of continuous duty air stripping, but requiring minimal installation and field wiring. Operation of LO-PRO III(S) components is controlled with a Geotech Environmental Control Module (GECM) at the remediation site, which also allows remote monitoring of site activity.

The LO-PRO III(S) utilizes most of the equipment options offered by Geotech. Pre-wired and plumbed equipment includes a panel stand that supports the GECM, which contains the system motor starters, protection circuits, and control inputs. The GECM is also designed to control the effluent transfer pump with input from the sump level probe, as well as the influent pumps and probes when configured accordingly.

Theory of Operation

Many hydrocarbon contaminants such as benzene, toluene, and xylene can be volatilized when exposed to an air stream. Air stripping systems work by maximizing contact between air and the contaminated water to be treated causing the molecules of volatile contaminants to diffuse from the water into the air, which is then carried away.

Removal Efficiency

Removal efficiency is the difference in contamination level between the influent and effluent water streams. This difference is usually expressed as a percent.

For example, when the influent concentration of BTEX is 3000 ppb (parts per billion) and the effluent concentration is 3 ppb, the removal efficiency for BTEX is 99.9%. Removal efficiency is determined by two major system parameters; air/water ratio and water residence time.

Air/Water Ratio

Air/water ratio is the volume of air being pulled through the system per volume of water being treated. The air/water ratio is the CFM/CMM generated by the blower divided by the influent water flow rate in CFM/(GPM x .1337) or CMM/(LPM x 17.92). The air/water ratio is a measure of the amount of contact that takes place between air and water at any one moment in time.

Residence Time

Residence time is the length of time a given water molecule remains in the system from the time it enters the top of the air stripper until it falls into the sump. The longer the residence time the greater the potential for removal of volatile contaminants. In conventional packed tower air strippers, residence time is determined by the height of the tower and the water flow rate. In bubble plate air strippers like the LO-PRO III, residence time is a function of flow rate and the number of trays being used.

Multiplying the air/water ratio by residence time gives a measure of removal efficiency or the total amount of aeration experienced by a molecule of contaminated water as it passes through the system.

Packed Towers

In conventional packed tower air strippers, contaminated water cascades down through a tower filled with packing medium that exposes large surface areas of the water to an upward air stream. To obtain high removal efficiencies from such systems, packed towers as tall as 30 ft. (9 m) or 40 ft. (12 m) are sometimes required. This is because water residence time per unit packed towers is quite brief. Towers must therefore be tall to allow time for adequate stripping of contaminants.

In contrast, the LO-PRO III Air Stripper uses a unique multi-stage counter-flow aeration system that requires no packing medium and yields removal efficiencies of up to 99.99% from a unit that stands less than 9' (2.7m) high from top to bottom.

Figure 1-3 contains an example of the flow of air and water within the LO-PRO III system.




Figure 1-3: Process Flow Diagram of the LO-PRO III Air Stripper

Contaminated water enters the LO-PRO III at the top and slowly cascades down from tray to tray. While in each tray, the water is aerated by bubbles generated by the bubble plates mounted and sealed between each tray. The multi-stage counter flow design permits long water residence times and high efficiency stripping without the need for a tall packed tower.

System Components

Blower

The standard LO-PRO III uses a centrifugal blower to draw air through the bubble plates. The blower is mounted on a steel metal frame that also supports optional panels containing the following instrumentation: a standard Static Pressure Gauge, the optional HI and LO Vacuum (Pressure) Switches, and the optional CFM Gauge with filter. Explosion proof blowers are available for use in Class 1, Div. 1, Group C & D hazardous locations.



The optional GEKM is equipped with thermal overload connections when this feature is provided by the blower manufacturer.

Sump

The sump is 72" (183 cm) long, 60" (152 cm) wide and 16" (41 cm) high and is constructed of low density polyethylene (LDPE). It serves to collect treated water and support the aeration trays, blower assembly, and panel stands. Also molded into the exterior of the sump are holes for the intake and optional sump probe, and threaded holes for a sight tube and NPT fittings to attach a water effluent pipe.

Aeration Trays

The trays are constructed of LDPE and are molded for vertical stacking on top of the sump. They are secured to one another and to the sump by quarter-turn fasteners. Flexible gaskets on the mating surfaces assure an air and water tight fit between trays. The stainless steel bubble plates are designed to be sit between successive trays. This provides higher removal efficiencies and can be adjusted by changing the number of trays used with the system. The trays are 42" (107 cm) long, 60" (152 cm) wide and 13" (33 cm) high.



Alterations to LO-PRO III tray configurations will require changes to the bubble plate orientation and possibly the blower type. Consult with a Geotech Sales representative prior to modifying any existing unit.

Lid

The lid contains the polypropylene mist eliminator and fits on the top of the LO-PRO III unit. Constructed of LDPE, the cover is equipped with fittings for attachment of the influent water and effluent air plumbing.

Static Pressure Gauge

The provided static pressure gauge measures the difference between ambient air pressure and the pressure generated inside the system. The gauge reads in inches of water column and is connected by FEP tubing to a static sensor tip mounted in the blower influent air pipe.

Sump Probe

The LO-PRO III Sump Probe (Figure 1-5) monitors the water level within the sump and provides sensor input to the optional GE/CM.

The probe is density actuated and uses separate floats to control feed and transfer pumps. The bottom float controls operation of the optional transfer pump by actuating HI and LO switches located on the probe shaft (see Figure 1-5). The pump starts when the HI/LO level float rises to the HI switch and continues to run until the water level drops the float to the LO switch. The 4" (10 cm) HI/LO range on the probe results approximately to a 75 gallon (284 L) working sump capacity.

The top float actuates the HI OVERRIDE switch. If the sump should become full, the rising water level will lift this float and shut off the feed pump.

High and Low Vacuum (Negative Pressure) Switches

HI and LO Vacuum Switches are available to monitor the vacuum generated by the blower. In the event of a blower shutdown, the LO Vacuum switch signals the control panel to shut off the feed pump, thereby preventing untreated water from passing through the system.

If bubble plate fouling or water entrainment causes the vacuum in the system to rise, the preset HI Vacuum switch will signal the control panel to shut off the blower. This reduces the possibility of water being pulled into the blower. At the same time, the LO Vacuum switch will initiate when the blower stops. The feed pump will shut down, thereby preventing untreated water from passing through the system.

CFM (Air Flow) Gauge

The optional Cubic Feet per Minute (CFM) gauge measures the volume of air passing through the LO-PRO III system. The gauge is equipped with an air filter to prevent moisture from accumulating in the gauge. CFM gauges are matched to the specifications of the blower and LO-PRO III assembly. If this option is included, the Pitot tube is factory installed along the effluent pipe between the blower and lid to




Figure 1-5: LO-PRO III Sump Probe

ensure a correct flow reading on the gauge. Consult Geotech Sales when installing a CFM Gauge to your system.

Optional Components

Although the standard LO-PRO III can be plumbed, wired, and operated as delivered, the benefits of the system can be greatly enhanced by the addition of the optional accessories described in the following pages.

Geotech Environmental Control Module (GECM)

The Geotech Environmental Control Module (GECM) is a specifically designed, microprocessor based, industrial control panel for the operation of remediation and industrial equipment including, but not limited to Geotech branded equipment.

The GECM is designed for installation in an unclassified location, with Intrinsically Safe (IS) circuit extensions into hazardous (classified) locations.

The GECM has also been designed for ease of use and installation and can accommodate a wide variety of equipment control needs. A variety of equipment combinations can be controlled from just one control panel. A basic panel is capable of controlling up to eight devices from 24 IS probe inputs. Devices can vary from small signal relays to 75 HP motor starters. A panel can be easily expanded to accommodate up to 32 additional outputs and 96 additional IS probe inputs. This equipment should be installed in accordance with NEC NFPA 70.

A GECM Field Wiring Diagram is also included with each unit. The GECM Field Wiring Diagram illustrates the internal layout of the GECM and contains wiring information pertinent to device installation and troubleshooting.



Figure 1-4: Geotech Environmental Control Module

Hoses

HI and LO Vacuum switches are mounted to the lower backside of the black control panel so that they can be easily placed in line with the FEP tubing from the Static Pressure gauge before connecting to the Static Sensor Tip in the influent blower piping. Blue switch cabling will then connect to the optional Junction Box from which connection to a GECM or other control source can be made.

See *Section 4: System Maintenance* for more information on the HI and LO Vacuum switches and their operation.

Water Flow Meter

An optional water flow meter is available for mounting to the influent water connection on the LO-PRO III lid. The standard flow meter is a clear plastic flow meter with a weighted float that allows the operator to view water flow rate at the site. Other water flow measurement and monitoring options include flow totalizer with digital display of gallons pumped and water flow rate. Remote monitoring of totalizer pulses are available and can be included with the GECM. Geotech provides partial plumbing on the lid with a 2" (5cm) PVC slip fit union so that a flow meter can be easily attached.

Transfer Pump

Transfer pumps are surface mounted centrifugal pumps designed to move water from the sump of the LO-PRO III to a drain, storm sewer, or secondary treatment system. Transfer pumps can also be controlled with the GECM. See Figure 1-2 for a diagram of a typical LO-PRO III installation showing feed lines and transfer pump.

Section 2: System Installation



The LO-PRO III must be installed, operated, and maintained according to the procedures described in this manual. Failure to follow these procedures or to observe the Warnings and Cautions included in this manual may result in personal injury and will void the Standard Equipment Limited Warranty.



The standard LO-PRO III system is designed for installation and operation in a non-hazardous, non-classified location with intrinsically safe extension into a hazardous classified location. Geotech does not determine classification of a location. Check government regulations regarding hazardous area locations prior to installation.

Classification of location is subject to local jurisdiction enforcement of NFPA regulations. All installations should be performed in accordance with the National Electric Code (NEC) Handbook. Before deploying the LO-PRO III, confirm that the electrical service at the site is properly sized for the blower and/or optional GECM, and that it conforms to NEC and local codes.

Unpacking

Depending on the height of the unit, the system components are generally shipped on two separate pallets. One pallet contains the sump with the bottom tray, blower, and necessary controls already installed. The sump will be bolted to this pallet prior to shipment. The second pallet will contain the remaining trays and all plumbing.





If the total height of the unit with pallet does not exceed the maximum shipping height of the transport truck, then the unit will be shipped completely assembled.

Inspection

Inspect all equipment upon arrival. Check the contents of the packing crates against the Sales Order and the System Specification Sheet included with this manual. If any items are missing or damaged, make note of this on the shipping papers and immediately notify Geotech Environmental Equipment, Inc. in Denver, Colorado, USA at (800) 833-7958 or (303) 320-4764.

Deployment

Throughout the following installation procedures, refer to Figure 1-2 and 2-1, and when applicable, the GECM Field Wiring Diagram.



TOTAL TRAY STACK HEIGHT				
TRAY QTY.	2	3	4	5
13" (33 CM) TRAYS	57"/145 cm	70"/178 cm	83"/211 cm	96"/244 cm

Figure 2-1: LO-PRO III plumbing hookup diagram showing system dimensions and influent/effluent fitting locations

Mount the Sump

Place the shipping pallet with sump on a flat level surface capable of supporting the entire system when filled with water. The filled weight of the sump is approximately 1,525 lbs. (693 kg), while each aeration tray weighs approximately 128 lbs. (58 kg) when full. Given the additional weight of the blower and other system components, the total weight of an average 3-tray system is 2,100 lbs. (955 kg).



Leveling the sump is important: the LO-PRO III will function properly only if the tray stack is level.

Stacking the Trays

The sump will be shipped with the bottom tray, bubble plate, and downcomer pre-mounted and properly oriented. Depending on the height of the unit, the system may be completely assembled and ready to go upon arrival.

Carefully record the orientation of the bubble plate that is mounted between the sump and the first tray. Each bubble plate has a downcomer attached. The remaining trays are then stacked so that the positioning of the downcomers alternate from one side of the bubble plate to the other. Tray orientation will be correct upon receipt, but it is good to record the orientation should the unit be disassembled for cleaning.

Use the following method to properly stack trays:

- If the unit has an even number of trays (not counting the lid), then the first bubble plate is to be placed with the downcomer towards the front (or blower side) of the unit.
- If there is an odd number of trays (not counting the lid), then start the downcomer towards the back by flipping the bubble plate over and re-installing the downcomer.

Trays are to be stacked individually to assure that each bubble plate is centered. Stack the remaining trays and bubble plates on top of the sump, and place the lid on top of the topmost tray.

The downcomer openings are to face to the right (as you look at the unit from the blower side). The objective to alternating the downcomers is to evenly distribute the flow of water through the system and to end up with the last bubble plate's downcomer placed towards the back of the unit. When the lid is attached the influent water connection will not pour directly into an open downcomer, bypassing the first bubble plate. A bubble plate is not installed between the top tray and lid.

The bubble plate used on the LO-PRO III is universal and can be flipped over to place the downcomer towards the front or back. Trays can be added or removed and the bubble plates re-arranged accordingly. The first downcomer installed to the sump is taller than the rest.

Ensure all trays are aligned before locking the clamps in place.

Install the Lid

Verify that the water catch basin is secured to the front, right side of the last tray with two screws. The basin is for catching the influent water stream. Verify that the internal plumbing on the lid is set at a 45° angle to the outside (or towards the water catch basin) when the lid is in place. The mist eliminator will

already be strapped to the lid from the factory. Ensure the lid is aligned to the top tray before locking the clamps in place.

Install Plumbing

1. If not connected, install the blower influent pipe between the 6" flexible couplings on the lid and blower.
2. Connect the influent water line and optional flow meter to the 2" slip fit union on the lid.
3. Run an effluent water pipe from the sump to a suitable receptacle or to a transfer pump for discharge to another location. Two 3" FPT ports are provided on the sump for attachment of an effluent water pipe. These ports are located on opposite sides of the sump. Check local codes before plumbing effluent pipe.

Air Intake

The LO-PRO III comes with a screened air intake shroud. A mating flange can be installed when necessary to run ducting to an external air source.

Connect Exhaust

Make any necessary exhaust connection to the fan AIR OUT opening on the blower. Route exhaust air to a separate collector or as required by local codes.

Wiring



All wiring must be carried out by a qualified electrician and be in accordance with government codes.

Install GECM

Even though the GECM electronics are enclosed within a NEMA 4 rated weatherproof box, it is advised that you place your GECM within a sheltered area, protecting the unit from direct exposure to water and sunlight.



Power must be disconnected and locked out at the panel or services before any installation procedures are attempted.

See *Appendix C: GECM System Installation* for further installation instructions.

Wire Blower

The LO-PRO III is normally equipped with a 10HP, TEFC, 230/460 VAC, 3-Phase blower. The blower can be wired directly to a local power source or it can be operated and controlled with the optional GECM.



When the blower is wired directly to a local power source, thermal overload protection (when accompanying the blower electrical) needs to be properly wired to the motor starter by a qualified electrician.

Because each GECM is unique to the system(s) they operate, Geotech provides the customer with a GECM Field Wiring Diagram showing all wiring connections between the GECM and the system. The GECM is equipped with latching overload protection that will prevent the blower motor from restarting until the panel control switch is manually reset.

Wire Sump Probe & Vacuum Switches

If your LO-PRO III is equipped with the sump probe and HI/LO vacuum switches, the leads from these components will be wired into a junction box mounted to the system control panel. The customer must wire from the junction box to the control panel (Figure 2-2) or as shown in the GECM Field Wiring Diagram. Figure 2-4 shows an example of the interior of a standard LO-PRO III junction box.




Figure 2-2: Wiring Diagram for the LO-PRO III sump probe and HI/LO vacuum switches.
**Refer to the GECM Manual or GECM Field Wiring Diagram for connections to the GECM.*




Figure 2-3: LO-PRO III junction box with HI/LO Vacuum switch and sump probe wiring plus cable connection to optional GECEM

Connect CFM Gauge

If your system is equipped with the CFM gauge, use the flexible FEP tubing provided to connect the gauge to the Pitot tube. Both the gauge and the Pitot tube are equipped with push-in fittings. When cutting and fitting the flexible tubes, ensure that they are not cut so short as to cause binding or kinking. Tubing should hang between both points and away from the blower body.



The tubing must be installed as shown in Figure 2-4.




Figure 2-4: Air lines and Pitot tube connection to the CFM gauge



Not all CFM gauges are designed to work with all Pitot tubes. Readings can be off when mismatched. Consult Geotech for the correct application. Tubing connections between the CFM gauge and Pitot tube may need to be reversed for proper function. Ensure that both levers on the Pitot tube are open.

Install Flow Meter (optional)

If your system includes a flow meter, it must be installed in-line with the influent water source and in a vertical plane to ensure accuracy. Thread tape all fittings and hand tighten the connections. Over tightening can crack the flow meter.

Install Transfer Pump (optional)

To install a transfer pump with the LO-PRO III, refer to the separate GECM Field Wiring Diagram and to the paperwork provided with the transfer pump. Refer to Figure 1-2 for an example of a LO-PRO III installed with a transfer pump. Effluent connections at the pump can be made off the valve assembly at the top of the transfer pump. Plumbing considerations are dependent upon the site configuration.

Section 3: System Operation

Startup

Once installation has been completed, the LO-PRO III is ready for startup. Proceed as follows:

1. Double check all electrical and plumbing connections.
2. Close the water flow control valve (if present).
3. Start blower and check air flow direction (blower rotation). If using 3-Phase power source, a qualified electrician will need to adjust the leads.
4. With the water flow control valve slightly open, start the feed pump. Slowly open the water flow control valve until the desired flow rate is obtained.
5. Adjust the blower discharge blast gate so as to regulate the system current to the appropriate nameplate stated amps for the voltage.



If you are using a transfer pump and GECM, turn the control switch to AUTO before starting the feed pump. The transfer pump, in conjunction with the sump probe, will start when sufficient processed water has accumulated in the LO-PRO III sump.

Operation

Once startup has been achieved, LO-PRO III systems equipped with the optional GECM, sump probe and vacuum switches will function as shown in the system Process & Instrumentation Diagram (Figure 7-1).

- Secure blower blast gate position with the wing screw to ensure the appropriate amp draw at startup.
- Record system static pressure at startup obtained from included static pressure gauge.

Sump Probe

The controls enhance the efficiency and safety of the LO-PRO III system by coordinating the function of the blower, the feed pump, and the transfer pump.

The sump probe monitors the water level in the LO-PRO III sump and signals the transfer pump (via the control panel) to switch the pump ON and OFF in response to changes in water level. The probe also has a HI-OVERRIDE sensor that can shut off the feed pump if the water level in the sump rises too high and threatens to flood the blower.

High Vacuum (Pressure) Switch

If bubble plate fouling or water buildup in the trays causes the total system vacuum to rise over a predetermined limit (approx. 30" (7.5 kPa) of water column for 10HP blowers and 35" (8.7 kPa) for

15HP blowers), the HI Vacuum switch will shut off the blower. This will prevent water from reaching the blower.

Low Vacuum (Pressure) Switch

Should the LO-PRO III experience a power failure to the blower or have part of the vacuum tubing line cut, the system pressure will automatically fall below 1" (.3 kPa) to 2" (.5 kPa) of water column and the LO Vacuum switch will shut off the LO-PRO III control panel and feed pump. This will prevent untreated water from passing through the LO-PRO III system.

To restart the blower after it has been shut down by a LO or HI Vacuum condition, remedy the cause of the shutdown then turn the HOA switches for the blower and transfer pump on the GECM to OFF. Press the RESET button to clear the error then turn both switches back to AUTO.



If water intrusion into the blower piping is suspected, remove the effluent 6" (15cm) pipe at the blower and empty the piping of all water before starting the blower.

Blast Gate

The provided blast gate, located on the discharge side of the blower, is factory set to provide the appropriate amps of motor current with the dry systems. Geotech recommends resetting the blast gate to achieve the appropriate amps at the particular site of operation with water flowing through the system.



The amps will increase as the blast gate is opened. To avoid over-amping the system, always start with the gate half open. While using an amp probe on a power leg at the motor, adjust the gate for optimum air flow (30"/7.5 kPa for 10HP, 35"/8.7 kPa for 15HP) while monitoring the amps. Lock the blast gate in place after every adjustment.

GECM LOPRO Displays

Line 1 messages:

LOPRO: HI VACUUM	(fault)
LOPRO: LO VACUUM	(fault)
LOPRO: Lx Hx	
LOPRO: PROBEFAULT	(fault)
LOPRO: HI SUMP	(fault)
LOPRO: AUX ALARM	(fault)

Line 2 messages:

BLWRnnnnXFERnnnn

Where

x =H (high), M (middle), or L (low)
nnnn =ON, OFF or HAND

Telemetry Messages on GECM Display -

Each GECM unit equipped and enabled with Telemetry will send a text message to the programmed phone numbers for every condition and fault for the specific device listed in the previous pages. The battery backup will send an additional "Power On" and "Power Outage" text message to inform the user of power status. Additional display and details correlating to the Telemetry package are listed below. Custom units may have varying Display and Telemetry alerts.

Startup sequence:

```
Waiting on Modem
Startup
```

This indicates the modem is going through initiation routines and connecting to the cellular network. This will happen every time the system is powered on, and when telemetry is enabled through the keypad.

Sending SMS alert:

```
Sending msg #--
To phone [x] of [X]
```

This indicates the modem is currently sending a message to programmed phone numbers. Text messages correspond to the device and display definitions listed in the previous pages.

Receiving SMS Query:

```
Query [x] match
```

This indicates the modem has successfully received a query text message. This screen is followed by the "Sending SMS alert" display which is responding to the query.

System's response to text message "STATUS?" (case sensitive):

System Standby	System On, all HOA switches in the "OFF" position
System Running	One or all HOA switches in the "ON" position
System In Alarm	System experiencing fault, see last message received

If GECM is not responding to query messages, check that power is ON and that the antenna is attached. Damaged antennas should be replaced as soon as possible.

Section 4: System Maintenance

Cleaning the LO-PRO III Unit

The LO-PRO III is designed for trouble free operation with minimal maintenance required. The modular design of the system permits easy disassembly for inspection and cleaning.



Material removed from the LO-PRO III bubble plates during cleaning should be collected and disposed of in accordance with government codes. It is the customer's responsibility to determine if minerals deposited by the groundwater must be treated as hazardous waste.



Always wear eye protection, gloves, and proper clothing when performing maintenance procedures. Geotech recommends that the appropriate personal protective equipment (PPE) for cleaning LO-PRO III trays should be at USEPA Level D Protection modified with splash protection as follows:

- Hard hat with splash shield
- Splashguard goggles
- Waterproof coveralls
- Waterproof gloves
- Waterproof boots

At sites where toxic chemicals are present in the water being treated, upgraded PPE (e.g. air purifying respirator, chemical resistant gloves, etc.) may be required.

Sump, Tray, and Lid Cleaning Procedure



When performing regular maintenance, be careful not to damage the gaskets by placing or sliding the lid or trays on the ground or rough surface. A set of gaskets is glued to each tray and should be cleaned separately with a soft cloth. Replacement gasket kits can be obtained from Geotech.

Bubble plates will require maintenance on a regular basis. If the holes in the bubble plates begin to clog due to buildup of organic or inorganic material in the water, the HI Vacuum switch will repeatedly shut down the system. When this happens, it is recommended that the aeration trays, bubble plates, and downcomers be disassembled and cleaned as follows:

1. Numerically mark the outside of the trays so that re-assembly will be easy. Do this for each bubble plate also so that the orientation can be properly restored when reassembled. When necessary, use the instructions outlined in *Section 2: System Installation*, "Stacking the Trays".
2. Disconnect the 6" (15cm) PVC pipe from the lid and blower. Visually inspect the interior for debris and clean as needed.
3. Disconnect the union for the influent water connection. If using a flow meter, you may want to clean it while it is off the system.
4. Remove the lid, then remove the mist eliminator from the lid. Clean the lid and mist eliminator with hot water and soap. Inspect the internal PVC plumbing for any obstructions.



Degreasers such as phosphate free detergent can also be used in breaking up hydrocarbon build up on the interior parts.

5. Remove the trays and bubble plates. Clean all parts using a brush with hot water and soap. Rinse thoroughly. As you remove and clean each tray and bubble plate, set them aside in a row for easier reassembly.
6. With the trays off the sump, inspect the interior and remove any accumulated debris. This prevents any clogging of the transfer pump.
7. Inspect the screen on the influent air intake shroud and remove any debris from the screen.

Mist Eliminator Maintenance

Clean the polypropylene mist eliminator on a regular basis. The required frequency of cleaning should be evaluated on a site-by-site basis, as frequency of cleaning depends on water chemistry and other factors. Figure 4-1 shows the location of the mist eliminator and retention hardware.




Figure 4-1: The LO-PRO III mist eliminator.

1. Loosen the retaining clips and lift the entire lid assembly (cover) from the LO-PRO III.
2. Remove the four (4) #10 sheet metal screws that secure the retention straps.
3. Pull the mist eliminator from the lid assembly.
4. Tap the demister against a sturdy surface to dislodge any large particles that are trapped within the mesh.
 - When possible, completely soak the mesh and frame in a degreaser such as phosphate free detergent or safe, non-toxic degreaser.
5. Rinse the mist eliminator with clean water and allow it to dry.
6. Replace the mist eliminator in the lid assembly and secure the retention straps with the screws.
7. Check and clean the influent water catch basin in the top tray.
8. Replace the lid assembly and tighten the retaining clips.

Reassembling the Trays and Lid



When reassembling the LO-PRO III, be sure the gaskets are clean and have no tears or gaps to eliminate any potential air leaks between trays.



Refer to the instructions outlined in *Section 2: System Installation*, “Stacking the Trays”, in conjunction with this section when re-assembling the LO-PRO III Trays.

Trays and bubble plates with downcomers need to be restacked to the sump in the order they were removed. Orientation of the bubble plates is critical in that the downcomers attached need to alternate from front to back. One downcomer (the one attached to the bubble plate for the sump) is taller than the rest and must go with the first bubble plate. Figure 4-2 shows the two kinds of downcomers used on the LO-PRO III system. See *Section 8: Replacement Parts and Accessories* for a listing of part numbers.

In order to determine whether or not to place the downcomer for the first bubble plate toward the front or the back, note the following:

If the LO-PRO III has an even amount of trays (4), place the first downcomer toward the front (or blower side) of the unit and to the right side of the sump (as shown in Figure 4-3). If the LO-PRO III has an odd amount of trays (3, 5), place the first downcomer towards the back. Then alternate the bubble plate openings and downcomers front to back. When attaching the lid, there will be no downcomer below the water influent plumbing.



Never stack downcomers over one another. All bubble plates and downcomers are to alternate front to back, with the last bubble plate downcomer in back.

As you stack each tray, look at the alignment from all sides before completely latching the tray into place.

Finally, attach the lid. Verify that the mist eliminator is clean and securely strapped to the center hole inside the lid. Set the internal plumbing of the lid to a 45° angle, or towards the water catch basin within the top tray, then place the lid on, center it, and latch it into place.




Figure 4-2: LO-PRO III Downcomers



Figure 4-3: First Bubble Plate on Sump

Clean Sump Probe

On a regular schedule, remove and wash the sump probe in phosphate free detergent and hot water. This will prevent fouling that could lead to failure of the probe. The required frequency of cleaning is dependent upon water chemistry, temperature, and other factors that must be evaluated on a site-by-site basis.

Drain Vacuum (Pressure) Switches

The HI and LO Vacuum switches should be drained on a regular basis. This is particularly important in applications where excessive condensation may cause a buildup of moisture within the switch. To drain the switch, rotate the vent drain plug (underneath) one turn in a clockwise direction and then return the plug to its original position. See Figure 4-4.



Figure 4-4: Static Sensor Tubing between gauges and switches (CFM gauge tubing not shown)

Drain CFM Gauge Air Filter

The filter on the CFM gauge should be checked on a regular basis and drained if necessary. Drain the filter by turning the drain screw (underneath) in a clockwise direction (when viewed from the bottom of the filter.) Close the drain by turning the screw counter-clockwise. See Figure 4-4.

Check FEP Tubing

Regularly check the condition of the FEP tubing going from CFM gauge to Pitot tube and between the static pressure gauge, vacuum switches and static sensor tip in the influent piping. A cut, kink, or loose tubing connection can cause operational problems with the LO-PRO III. See Figure 4-4.

Operation of the HI/LO Vacuum Switches

Though the HI and LO vacuum switches are called out as *Pressure* switches, and can be used as such, their application with LO-PRO III systems are to be used as *Vacuum* (negative pressure) switches. When you see the word *Pressure*, assume *Vacuum* unless the step is defining a physical port on the switch itself, in which case the word *Pressure* is used.

LO-PRO III “HI Vacuum” (pressure) switch

The HI vacuum switch used is always wired for *Normally Closed*. The switch will remain closed until you adjust the vacuum setting screw to have the switch *Open* at a specific vacuum (negative pressure) reading (in inches) on the Static Pressure gauge. This is achieved by turning the set screw clockwise for a higher setting, counter-clockwise for a lower setting. When this setting is reached, the electrical contact will *Open*, breaking the circuit and, in most applications, shutting the system down.

LO-PRO III “LO Vacuum” (pressure) switch

The LO vacuum switch used is always wired for *Normally Open*. Once a measureable amount of vacuum (1”/.3 kPa to 2”/.5 kPa or greater negative pressure) builds up within the unit, the switch will close and remain closed until you adjust the vacuum setting screw to have the switch *Open* at a specific lower vacuum. This is achieved by turning the set screw clockwise for a higher setting, counter-clockwise for a lower setting. The GECM is preset to allow enough time for this switch to close as the unit is powered up. The electrical contact will *Open* when the lower vacuum setting is reached, breaking the circuit.

- It’s called a pressure switch, but it all depends on how the system is plumbed. The “HI PRESSURE” port is used for positive pressure readings, the “LO PRESSURE” port is used for vacuum (negative pressure) readings.
- All switches are wired to be physically *Closed* without pressure (vacuum) applied, except for the LO Vacuum (pressure) switch, which is wired *Normally Open* and immediately closes with the first sign of vacuum (negative pressure).
- The blower sucks air through the LO-PRO III system, thus the *Vacuum* reference.

HI Vacuum Switch Setting

HI Vacuum switches are pre-set at the factory to not exceed 30” (7.5 kPa) Static Pressure on 10HP blowers or 35” (8.7 kPa) on 15HP blowers. The purpose of this setting is to maximize contact between the air and the contaminated water to be treated, as described in *Section 1: System Description*. Before proceeding with an adjustment, read the literature that came with the switch from the manufacturer.

When adjusting your HI Vacuum switch, use the following steps either to verify the current setting, or to make an adjustment to the HI Vacuum switch (such as after replacing a faulty switch):

1. Turn off the blower. Turn off the influent water to the lid.
2. Disconnect the 6” (15cm) PVC influent pipe from the flexible coupling on the lid and tilt the pipe outward, clearing the coupling.
3. At the junction box remove the black and purple wires for the switch and attach an Ohmmeter to the ends of each wire. The Ohmmeter will show a *Closed* circuit with the blower off.



If over-amping is a concern then it may be necessary to have an electrician open the blower motor electrical box and attach an amp probe to a power leg to verify that the name plate amps are not exceeded while adjusting the blast gate for 30” (7.5 kPa) or 35” (8.7 kPa).

4. Place a jumper on the circuit for the HI Vacuum switch at the junction box so that the GECM (if supplied) will not turn the system off during the test.

5. Adjust the blast gate to half way, then turn on the blower.
6. Adjust the blast gate at open flow so that the amp reading is just one (1) value under the nameplate amps specified on the blower, then lock the blast gate in place. Proceed with one of the following options:

Option 1 - Verifying the current setting of an existing HI Vacuum switch

1. With the blower running, gradually cover the 6" (15cm) inlet pipe with a hard flat object.
 - DO NOT use your hand
2. Monitor the increase in vacuum on the Static Pressure gauge.
 - Also, monitor the amp reading while doing so
3. When the Ohmmeter shows *Open* the inches shown on the gauge will be your current setting.
 - If the Ohmmeter does not show an *Open* after reaching the correct inch setting or upon reaching the name plate high amps, then the switch is either set too high or the switch is stuck
 - A stuck switch needs to be replaced.
4. Adjust the switch by turning the Set Range screw on top counter-clockwise for a lower vacuum setting, clockwise for a higher vacuum setting.
 - DO NOT adjust with pressure on the switch.



Some LO-PRO III systems may not reach the maximum inch setting specified for the HP of the blower. If so, then set the switch for the highest setting you can get minus 2" (.5 kPa). For example, if the maximum reached is 27" (6.7 kPa), then set the HI Vacuum switch to open at 25" (6.2 kPa).

5. The switch will be set when the circuit *Opens* at the correct inch setting
 - DO NOT over amp the blower.
6. Turn the blower off and restore all electrical connections.
7. If you have a GECM, turn the unit back on and cover the inlet pipe to verify that the GECM will turn off the system with the HI Vacuum setting
 - This will activate after 5 seconds after HI Vacuum is detected.
8. Re-connect the inlet pipe and restore the system for operation.

Option 2 - Adjusting the setting for a new HI Vacuum switch

1. Turn the set screw all the way counter-clockwise.
 - The switch will show *Closed* on the meter.
2. With the blower running, gradually cover the 6" (15cm) inlet pipe with a hard flat object until the Static Pressure gauge reaches the desired setting.
 - DO NOT use your hand
 - DO NOT let the amps exceed the blower specifications.
3. With the switch all the way counter-clockwise, the meter should already show an *Open* circuit.
4. Leave the cover in place on the inlet pipe.
5. Using a flathead screwdriver, turn the set screw clockwise until the switch *Closes*.
 - This provides a range to make adjustments.

6. Turn the set screw back a few turns and continue to “fine-tune” the switch by removing and **slowly covering** the inlet pipe to verify the current setting.
7. Repeat and adjust the set screw as necessary.
 - The switch will be set when the circuit *Opens* at the correct inch setting without exceeding the amp limit of the blower.
8. Turn the blower off and restore all electrical connections.
9. If you have a GECM, turn the unit back on and cover the inlet pipe to verify that the GECM will turn off the system with the HI Vacuum setting
 - This will activate after 5 seconds after HI Vacuum is detected
10. Re-connect the inlet pipe and restore the system for operation.

Fan/Motor Maintenance

Lubricate fan or motor bearings to the manufacturer’s recommendations. Lubrication recommendations are included with the packet attached to the fan. Should the packet be missing, the following will apply:

HP Range	Standard Duty 8 Hr./Day	Severe Duty 24 Hr./Day Dirty Dusty	Extreme Duty Very Dirty High Ambients
10-40	3 Yrs.	1 Yr.	4 Mos.

Recommended motor greases:

- Polyrex EM – Exxon Oil Co.
- SRI #2 – Chevron Oil Co.

Do not over-grease the bearings. This is especially true if the bearings are not visible. Most bearing failures occur due to over-greasing than under-greasing. It is best to give the bearing a small drop of grease (using the previous table) while the system is warmed up and at a standstill.

Transfer Pump

If your system includes an optional transfer pump, the following routine maintenance tasks will help to ensure continuous service from the pump. Read the manufacturer supplied User Manual before proceeding.

- Check the flow rate weekly to ensure that the cycling frequency is minimized.
- Inspect hoses and wiring quarterly for cracks, cuts or abrasions.

Section 5: System Troubleshooting



These procedures are meant to be carried out by personnel qualified to work on electrical circuitry.

Getting Help

If the troubleshooting procedures in this section indicate a component failure, document the problem (as outlined below), then contact Geotech Sales for technical support.

Read the entire manual and become thoroughly familiar with all system components, system operation, and troubleshooting procedures. Prepare a written list of all problems encountered while operating the equipment.

Geotech service personnel are trained on all aspects of the LO-PRO III equipment line and are dedicated to helping you maximize the efficiency and cost effectiveness of your LO-PRO III system. Contact Geotech Sales for technical support of Geotech products.

Service Location

Geotech Service personnel are trained on all aspects of the LO-PRO III equipment line and are dedicated to helping you maximize the efficiency and cost effectiveness of your LO-PRO III system. For technical support of Geotech products contact us at the address listed below:

Geotech Environmental Equipment

2650 East 40th Avenue

Denver, CO 80205

Toll Free Phone: (800) 833-7958

Commercial Phone: 303-320-4764

Fax: 303-320-7242

Troubleshooting Procedures

The troubleshooting procedures outlined in this section assume that your LO-PRO III is controlled by an optional GECM panel and is equipped with the sump probe, vacuum (pressure) switches and water flow gauge. Troubleshooting procedures for LO-PRO III systems without these optional controls are appended at the end of this section.



If the LO-PRO III is operated by a GECM, then carefully read the troubleshooting section of the GECM User Manual before proceeding. Many of the display responses on the GECM front panel can easily be used to identify and isolate common problems.

The following troubleshooting guide contains potential problems with possible causes and recommended solutions. Before initiating troubleshooting, become familiar with proper installation and startup procedures as explained in *Section 2: System Installation* and *Section 3: System Operation* of this manual.

Problem: The blower will not run.

Cause 1: Loss of power to the blower.

- Check for status on GECM. If blank, check fuses and wiring connections.
- Check for tripped motor starter due to high amps.
- Check for thermal overload on blower motor.

Solution:

- Have qualified electrician inspect the electrical system. Verify amp settings on motor starter is correctly set for the blower motor specs.
- If there is power to the system and the GECM is not functional, contact Geotech Sales for technical support.
- Verify that blast gate has not opened all the way causing high amps.

Cause 2: The HI Vacuum switch has shut down the blower for one of the following reasons:

- Obstruction at the air intake portal.
- Water build-up (entrainment) within the aeration trays.
- Foaming in the trays or fouling of the bubble plates.
- HI or LO Vacuum switch out of adjustment (read section on vacuum switches within *Section 1: System Description*).
- Static sensor tubing line has been cut causing a LO Vacuum fault.

Solution:

- Check for water discharge at the blower effluent. If water is found, skip to Step 2. If water is not found, check the HI Vacuum switch as follows:
 - Disconnect the 6" (15cm) PVC blower influent pipe at the flexible coupling on the lid.
 - Turn the blower control switch to OFF, press RESET, then turn the switch back to AUTO to restart the blower. With the blower running, gradually cover the 6" (15cm) inlet pipe with a hard flat object (not your hand) and monitor the increase in vacuum on the Static Pressure gauge. Systems with a 10 HP blower should shut down at approximately 30" (7.5 kPa) water column (WC) or less while 15 HP blowers should shut down at approximately 35" (8.7 kPa) WC. If the blower fails to run or shuts off prematurely, refer to *Section 4: System Maintenance* and verify the adjustment of the HI Vacuum switch. If adjustment is not possible, the switch may be defective. Call Geotech Sales at 800-833-7958 or (303) 320-4764 for assistance.
- If water is found in the blower piping, proceed as follows:
 - Confirm that the water flow rate is below 60 GPM (227 LPM). If the flow rate conforms to specification, check for a stuck float in the optional water flow gauge.
 - If the gauge is functioning properly and the flow rate is correctly set, remove the lid from the top of the tray stack and confirm that the water distribution nozzle is directed into the water catch basin.
 - If the nozzle is properly positioned, disassemble the tray stack and check for fouling of the bubble plates.
- If the plates are fouled, clean according to the instructions outlined in *Section 4: System Maintenance* of this manual.

If the plates are not fouled, the water chemistry at your site may be causing foaming in the LO-PRO III. Call Geotech at 800-833-7958 or (303)320-4764 for assistance.



If the blower has taken on water, the Pitot tube and static tip must be cleaned before the system can be restarted. Remove the Pitot tube and static tip from the plumbing and use compressed air to blow any water from the tubes and air lines. Drain any liquid from the lines and vacuum switches.



Never blow compressed air directly into the gauges or vacuum switches as this may damage them.

Problem: Blower not running (system vacuum indicator showing)

Cause: The LO Vacuum switch has shut down the blower for one of the following reasons:

- Incorrect motor rotation.
- Obstruction at the blower effluent.
- Severed FEP tubing or disconnected tubing at Static Sensor.

Solution:

- Change the electrical leads on the motor to correct rotation.
- Clear obstructions from discharge line.
- Inspect FEP tubing for cuts or kinks.

Problem: Blower not running (thermal overload)

Cause: Shutdown caused by a blower thermal overload. Thermal overloads are usually caused by exceeding the full load amps setting on the adjustable thermal overload circuit. Proceed as follows:



Shut down all 3-phase power before opening any enclosure. Follow proper lockout/tag out procedures.

Solution:

- Confirm that the amp draw has not been exceeded. Refer to the blower motor nameplate for proper power supply requirements and adjust setting on the thermal overload circuit inside the motor starter enclosure.
- Check for high ambient heat levels.
- Check for minimum air flow requirement stamped on blower.



To restart the blower after thermal overload: Allow the motor to cool. Turn the blower control switch on the GEKM to OFF, press the REST button, then turn the switch back to AUTO.

Overheating can also be caused by an old or worn motor or insufficient cool air flow over the exterior of the motor.

Problem: Low removal efficiency

Cause: Reduced contaminant removal efficiency can be caused by a number of factors, some of which are listed as follows:

- Verify sizing program vs. actual influent contaminant levels.
- Water flow rates are improperly adjusted.
- Bubble plates fouled.
- Tower out of plumb.
- Low water temperature.
- Foaming in trays.
- Free or suspended product in influent water.
- Clogged mist eliminator.

Solution:

- Confirm water flow rate is below 60 GPM (227 LPM).
- Confirm that the tray tower is plumb.
- Clean mist eliminator using procedures outlined in *Section 4: System Maintenance*.
- Check for fouling of the bubble plates. Clean per procedure in *Section 4: System Maintenance*.
- Confirm that water temperatures have not deviated markedly from design parameters.
- Check for water entrainment caused by foaming. If foaming is suspected, call Geotech for assistance.
- At sites where contaminant is diesel or other heavy oil, check for presence of sheen in the LO-PRO III sump. If sheen is present, call Geotech for assistance.

Problem: Feed pump will not run

Cause: The feed pump is controlled both by its own control circuitry and by input from the LO-PRO III sump probe.

The feed pump will not run unless:

- Sufficient water is present in recovery well.
- The LO-PRO III blower is running.
- Power is present at feed pump control panel.

Solution: If these three prerequisites are met and the pump still will not run, proceed as follows:

- Check the water level in the LO-PRO III sump. If the water level is high, determine why the sump is not draining. Look for a faulty transfer pump, a clogged sump discharge fitting or a fouled sump probe (HI-LO float stuck down). If the water level is not high, check for a fouled sump probe (HI-OVERRIDE float stuck up).
- Check for a fouled feed pump probe or an electrical fault inside the feed pump control panel. Refer to the troubleshooting procedures provided with the feed pump.

Problem: Effluent pump will not run

Cause: The effluent transfer pump is controlled by either a GECM, its own control circuitry and by input from the LO-PRO III sump probe. The effluent pump will not run unless:

- Sufficient water is present in the sump.
- Power is present at the effluent pump control panel.
- Sump probe floats are not stuck.

Solution: If these prerequisites are met and the pump still will not run, check for a fouled sump probe or have a qualified electrician inspect the pump wiring and motor starter.

Problem: CFM Gauge Not Reading or Pegged Out

Cause:

- Tubing has been swapped or is cut or kinked.
- Valve handle(s) on Pitot tube are closed.
- Pitot tube has been turned in pipe.

Solution:

- Replace bad tubing.
- If gauge needle is all the way to the left or right, swap the tubing at the Pitot tube.
- Ensure both valve levers on the Pitot tube are set to open.
- Sensor holes on Pitot tube need to be in-line with the effluent air flow. Adjust Pitot tube as needed.

Additional Troubleshooting Procedures

The following procedures can be used to troubleshoot LO-PRO III systems that are not equipped with optional controls.



Exercise extreme caution when working with blowers and motor starters. Always follow all site lockout/tag out procedures.

Problem: Blower Not Running

Cause:

- Tripped circuit breaker at service.
- Blower shut down by thermal overload.

Solution:

- Reset breaker and determine reason for excessive current draw (see below).
- Determine cause of thermal overload by proceeding as follows:

Thermal overloads can result from bubble plate fouling or foaming in the trays. Fouling or foaming causes the blower to exceed its vacuum limits (30"/7.5 kPa to 35"/8.7 kPa of water) and eventually results in overheating and thermal overload shutdown. Thermal overloads can also be caused by high ambient temperatures around the blower.

Although most LO-PRO III blowers are not equipped with thermal overloads, heavy vacuum demands caused by bubble plate fouling or foaming will cause these blowers to heat up and draw excessive current. This will eventually cause the circuit breaker at the service or motor starter to blow.

Proceed as follows to eliminate the cause of the blower shutdown:

- Disassemble the tray stack and check bubble plates for fouling. If the plates are fouled, clean as instructed in *Section 4: System Maintenance*.
- If the plates are not fouled, check for water buildup (entrainment) caused by foaming. To do this, turn off the influent water supply and remove the bottom of the effluent 6" (15cm) pipe from the back of the blower. If water is found, chemicals at your site are causing foaming inside the LO-PRO III. Call Geotech for assistance.

GECM Troubleshooting

Use this section, in conjunction with the Display Definitions found in Appendix B, to troubleshoot any occurring system problems.



The RESET button must be depressed to clear a system fault or condition. This will also automatically restart any devices still set to AUTO.

No Apparent Power to the GECM

- Check all incoming wire connections.
- Check fuses and breakers at power source. (Fuses can also be found on the GECM PCB. These can blow from a voltage spike or incorrect voltage applied to the GECM. Allow a Geotech technician to service these fuses.)

No Display

- Press RESET button (also used to clear the screen).
- Fuse is blown in the GECM PCB or faulty electronics. Return to Geotech for service.

Product Pump Will Not Run

- Check device status at GECM.
- Check for blown fuses (especially at power supply).
- Check for a bad relay connection between GECM and power supply.
- Check wire connections between device and GECM.
- Check reservoir probe floats and verify that nothing is obstructing their movement.
- Check probe wiring to GECM.

Water Pump Will Not Run

- Check device status at GECM.
- Check for blown fuses.
- Check wire connections between device and GECM.
- Check reservoir probe floats and verify that nothing is obstructing their movement.
- Check water level probe floats (when separate water pump in use).
- Check probe wiring to GECM.
- Pump may have over-amped due to obstruction, dry running, or damage. Inspect pump and flow route.

Dry Contact Message

- Check for circuit conflicts between GECM and other devices or switches.
- Have the logic statements and operation of any custom built devices checked.

Probe Fault

- This error will occur when the HI-HI float is in the up position and the HI/LO float is in the down position. Check for free movement on all floats.
- A switch wire may have become disconnected or broken.

Override Message

- Water override float is down and the HI/LO float is up. Check for free movement on all floats.
- A switch wire may have become disconnected or broken.

Tankfull Message

- Product recovery tank is full.
- A switch wire may have become disconnected or broken.

Auxiliary (AUX) Alarm Message

- External system has sent a dry contact message to the GECM, instructing the GECM to shut down. Ensure external system's faults are cleared in order to resume normal operation.
- A wire may have become disconnected or broken, check wiring diagram.

Section 6: System Specifications

This page lists all the standard components and optional accessories included with your LO-PRO III Air Stripper. Geotech part numbers for the optional equipment listed can be found in *Section 8: Replacement Parts and Accessories*.

Blower Model: _____

Blower horse power: 10 HP _____ , 15 HP _____

GECM (optional)* _____ (see specification sheet provided with GECM)

*When used with the GECM, the LO-PRO III must be equipped with HI and LO Vacuum switches and a sump probe.

_____ HI Vacuum Switch

_____ LO Vacuum Switch

_____ Sump Probe

_____ Transfer Pump

_____ CFM Gauge

_____ Junction Box

_____ Flow Meter

Dimensions

Length: 72" (183 cm)

Width: 60" (152 cm)

Number of trays: _____

Height: _____ (see *Section 2: System Installation*)

Materials of Construction

Sump, trays and lid:

Linear Low Density Polyethylene

Bubble Plates:

Stainless Steel

Influent and effluent plumbing:

PVC

Performance

Water Flow Rate:

1-60 GPM (4-227 LPM)

Removal Efficiency:

Up to 99.99% for BTEX

Air Flow Rate:

Blower Efficiency Dependent

Blower

Type:

Centrifugal blower (TEFC: for use in Class 1, Div. 2 locations)

Flow Rate:

Up to 1100 CFM (31 CMM)

Voltage:

208-230/460

Phase:

3

HP:

10 – 15


Environmental

Max Operating Temperature:

122°F (50°C)

PERFORMANCE DATA						
SCFM	SP	RPM	BHP	TEMP	ALT	DENSITY
800	38.5	3500		70	0	0.0750

MOTOR DATA						
HP	FRAM	RPM	VOLTS	PHASE	HZ	ENCL
10	215T	3500	208 OR 230/460	3	60	TEFC
10	215T	3500	208 OR 230/460	3	60	XPRF



A Size = VP-3-06-22.5A RPM = 3500 Density = 0.0750 lb./CF; Width = 100.00% SEA LEVEL

B Size = VP-3-06-22.5A RPM = 3500 Density = 0.0624 lb./CF; Width = 100.00% 5300 FEET

Figure 6-1: LO-PRO III 10 HP Blower Performance Curve

LO-PRO III Wiring Diagrams

All LO-PRO III systems using a GECM will have a GECM Field Wiring Diagram provided detailing all wire connections to the unit. This diagram can be updated or replaced as needed by Geotech.

Without the use of a GECM, the on-site electrician will need to wire the blower motor to an appropriate motor starter and power service. The wiring from the LO-PRO III junction box containing the wiring from the vacuum switches and sump probe, along with the motor thermals, must be integrated as a system shutdown component to the motor starter circuit in order to terminate power in the event of equipment failure.

Geotech can also build unit specific start boxes for use with the LO-PRO III, transfer pump, and accessories. Contact Geotech for more information on system requirements. Figure 6-1 contains basic wiring for a 3-Phase blower (examples do not include junction box integration).




Figure 6-2: Basic 3-Phase Wiring Diagram

GECM Specifications

Customer and Device Information

Customer Name:

Sales Order Number:

Build Date:

GECM Serial Number:

Device Name:	Serial Number:	Model Number:

Terminal A – IS Inputs

Lower Tier (1 thru 20)

1		IS +5VDC
2		IS +5VDC
3		IS +5VDC
4		IS +5VDC
5		IS Input
6		IS Input
7		IS Input
8		IS Input
9		IS Input
10		IS Input
11		IS Input
12		IS Input
13		IS +5VDC
14		IS +5VDC
15		IS +5VDC
16		IS +5VDC
17		IS +5VDC
18		IS +5VDC
19		IS +5VDC
20		IS +5VDC

Upper Tier (21 thru 40)

21		IS Input/ Water Sensor Input
22		IS Input/ Water Sensor Input
23		IS Input/ Water Sensor Input
24		IS Input/ Water Sensor Input
25		IS Input
26		IS Input
27		IS Input
28		IS Input
29		IS Input
30		IS Input
31		IS Input
32		IS Input
33		IS Input
34		IS Input
35		IS Input
36		IS Input
37		Normally Closed
38		Normally Closed
39		Normally Closed
40		Normally Closed

Terminal C - Relay/Motor Starter Control Outputs

(1 thru 8)

1		Relay/Motor Starter Control Output
2		Relay/Motor Starter Control Output
3		Relay/Motor Starter Control Output
4		Relay/Motor Starter Control Output
5		Relay/Motor Starter Control Output
6		Relay/Motor Starter Control Output
7		Relay/Motor Starter Control Output
8		Relay/Motor Starter Control Output

Terminal D – HOA Switch Inputs

(1 thru 24)

GND		Ground
1		Input
2		Input
GND		Ground
3		Input
4		Input
GND		Ground
5		Input
6		Input
GND		Ground
7		Input
8		Input
GND		Ground
9		Input
10		Input
GND		Ground
11		Input
12		Input
GND		Ground
13		Input
14		Input
GND		Ground
15		Input
16		Input

LOPRO 3 Specifications and Test Form

LOPRO serial number:	
Blower model:	
Blower serial number:	
Nameplate volts:	
Nameplate amps:	
Horsepower (HP):	
Phases (PH):	
Voltage unit was tested with:	
Number of trays on unit:	
Amp draw at open flow:	
(L1) amps:	
(L2) amps:	
(L3) amps:	
CFM at open flow (detached from lid):	
System vacuum (in inches of water) at open flow:	
Maximum vacuum (in inches) when blocked:	
HI vacuum switch set to (in inches of water):	
Amp draw at high vacuum setting:	
(L1) amps:	
(L2) amps:	
(L3) amps:	
LO vacuum switch set to (in inches of water):	
Ambient air temp at time of test (degrees):	
Air open flow output temp after 1 hour (degrees):	

Transfer Pump Specifications

Pump model:	
Pump serial number:	
Nameplate volts:	
Nameplate amps:	
Horsepower (HP):	
Phases (PH):	
Operational voltage unit is wired for:	

Section 7: System Schematic

System Configuration

Since the LO-PRO III is designed with the flexibility to cover a wide variety of applications, many different system configurations are possible. The System Specification sheet for your LO-PRO III can be found in *Section 6: System Specifications*. System dimensions and locations of influent/effluent water and air hookups are provided in Figure 1-2 and 2-1. Figure 7-1 contains the Process & Instrumentation Diagram for a standard LO-PRO III with optional controls.




Figure 7-1: The LO-PRO III Air Stripper P & ID showing optional controls and accessories.

Section 8: Replacement Parts and Accessories

Parts Description

Parts List

LOPRO III, 2 TRAY SYSTEM	1450002
LOPRO III, 4 TRAY SYSTEM	1450003
LOPRO III, 5 TRAY SYSTEM	86140000

Blower Assebly

ASSY, BLOWER, LP3, 10HP, 208V, TEFC	2459021
ASSY, BLOWER, LP3, 10HP, 230V 230/460V XP	2459013
ASSY, BLOWER, LP3, 10HP, 208V, XP	2459020
ASSY, BLOWER, LP3, 10HP, 380V, 3PH, 380V 50HZ TEFC	56140005
INSTRUMENT PANEL ASSY	2450022

GECM for Air Stripper

GECM, AIR STRIPPER	86110011
--------------------	----------

Other Options

ASSY, TRANSFER PUMP, 2HP, 230V	24500021
ASSY, TRANSFER PUMP, 2HP, 230V, 380V 50HZ TEFC	56040004
PANEL STAND, ASSY, SGL SITEPR	2459009
FLOWMETER, 20-60 GPM, RTOMETER	2459003

Replacement Parts

TANK,SUMP,72"x60"x16"HIGH	10263
TRAY,42"x60"x13"HIGH	10262
GASKET,LOPRO III TRAY,3 PIECE	PPM019008
BUBBLE PLATE,SS4,38.50x56.25	10284
DOWN COMER ASSY,SUMP LOPROIII	2450012
DOWN COMER ASSY,POLYPRO	2450000
PIN,STABLIZER,FOR LOPRO TRAY	10376
LID,42"x60"x15"HIGH	10261
MIST ELIM,12"x32"x4"THK	10872
STRAP,DEMISTER RETENTION	10695
ASSY,BASIN,TOP TRAY	2450005

Control Panel and Instrumentation

PANEL,MOUNTING,LOPROIII,GAUGE	56140002
SWITCH,PRESS,0.4-1.6"WC	PPE080006
SWITCH,PRESSURE,DIFF,10-180"WC EXPL PROOF, H3 SER,H3A-1SL,DWY	16090265
LO PRESS. SHUT DOWN ASSY:	2100074
ASSY,SHUT DOWN,HIGH PRESSURE	2100075
GAUGE,VACUUM,0-50"WATER-0-12KP	PPP082023
SENSOR,STATIC TIP,W/HOSE	56080006
GAUGE,FLOW,0-1000 CFM & M3/MIN	10715
FILTER,AIR,.175"NPT,20CFM	10315
SENSOR,FLOW,6",SST,PITOT	10631
JB,SITEPRO SGNL	2390065
CABLE,28AWG,8 COND,URETH	ORS418005
FERRULE WIRE,COPPER,26-22AWG 1 PACK OF 100	10032
PROBE,DENS,SUMP	2450014

Air Line

TEE,1/8"NPTx1/4"TUBE	PPP105002
----------------------	-----------

QCK CNCT,NCKL,1/4X1/8MPT,PUSH/ PULL TUBING,FEP,.170x1/4,FT FEP	PPP103001 87050509
---	-----------------------

Blowers

BLOWER,10HP,TEFC,208/230/460/3 /60HERTZ 800 CFM @ 32" WATER	10871
BLOWER, 10HP, 230-460V, EP	10874
BLOWER, 10HP, 208V, 3PH, EP	10657
BLOWER, 10HP, TEFC, 380V, 3PH, 50HZ 800 CFM @ 32" WATER	16140001

Transfer Pumps

PUMP,2HP,230V,3PH,TEFC	10665
------------------------	-------

Accessories

ELBOW,PVC80,6",SxS	10592
PIPE,PVC80,6",GRAY,CLEAN, INDIVIDUALLY WRAPPED,NO PRINT	PPP035033
COUPLING,FLEXIBLE,6"x6"	10593
UNION,PVC80,2",SXS	PPP053004
PIPE,PVC80,2"	PPP035001
FRAME,BLOWER TO SUMP,PAINTED	10655
FRAME,BLOWER,VERTICLE,PAINTED	10627
SHROUD,AIR INTAKE,LP3	10611
MANUAL,LO PRO III	10609
LATCH, BRS, HARDWARE KIT, LOPRO 1/4 TURN, KIT	10736

Contact your Geotech Sales Representative for more information on GECMs and other electrical features, including our variety of Water Table Depression Pumps, supporting the LO-PRO III System.

Appendix A – GECM Logic Statement

Low Profile (LOPRO) Air Stripper with Effluent Transfer Pump GECM Logic Statement

System Overview

A Geotech Low Profile Air Stripper (LOPRO II or III) system consists of a vacuum pump/blower, inlet and outlet plumbing with vacuum gauges and corresponding switches, multiple aeration trays with integral gaskets and latches, a sump, a lid (cover) with mist eliminator. A Transfer Pump pumps effluent fluid from the Sump according to the Sump Probe. The Geotech Environmental Control Module (GECM) provides automated control for the LOPRO's devices and switches.

GECM Control Panel Components

- (2) Hand/Off/Auto switches (1 for Blower, 1 for Transfer Pump)
- (2) Motor Starters with thermal overload protection (1 for Blower, 1 for Transfer Pump)
- Thermal overload motor coil protection (when applicable)
- Reset Button
- 4-button Keypad
- Dry Contact for control of influent pump

GECM Control Indicator Components

- 16 X 2 character LCD Screen
- (2) Green Run Lights (1 for Blower, 1 for Transfer Pump)
- (2) Red Fault Light (1 for Blower, 1 for Transfer Pump)

System Operation

Abbreviations used:

HI = High
LO = Low
BLWR = Blower
XFER = Transfer
OL = Overload

Sump Probe

The LOPRO Sump Probe is equipped with two floats that rise and fall with the water level in the sump. The bottom float controls operation of the transfer pump by actuating HI and LO switches on the probe shaft. The pump starts when the float rises to the HI switch and continues to run until the water level drops the float to the LO switch.

Water Hi-Hi Alarm

If both floats on the probe rise to the top of their travel, a Hi-Hi switch will actuate. The blower will shut down but the transfer pump will continue to operate until all floats reach the bottom of their travel, emptying the sump. The LCD screen on the GECM will indicate a "WATER HI-HI" alarm condition and the Red Transfer Fault Light will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Tankfull Alarm

A second probe may be used to shut off the appropriate devices for the system when the customer supplied recovery and/or holding tank becomes full. This tankfull probe is a single float activated level sensor installed in the top of the recovery and/or holding tank. When the float rises to the top of its travel. The LOPRO blower and transfer pump will shut down. The LCD screen on the GECM will indicate a "TANKFULL" alarm condition and both Red Fault Lights will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.




Figure A-1: Alarm Conditions

Probe Fault Alarm

A Probe Fault Alarm condition can occur in the sump probe when:

- There is non-sequential movement of the floats and switches
- The probe is installed to the GECM incorrectly
- There's a break in the wiring
- There's a break in the probe itself

The Probe Fault alarm condition will shut down the system. The LCD screen on the GECM will indicate a "PROBE FAULT" alarm condition and the Red Fault Lights will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Hi Vacuum Switch

In the event of a high vacuum condition in the LOPRO trays, the high vacuum switch will activate sending a signal to the GECM. The LOPRO will shut down but the transfer pump will continue to operate until the floats return to the bottom of their travel emptying the sump. The LCD screen on the GECM will indicate a "HI

VACUUM” alarm condition and the Red Blower Fault Light will illuminate. This alarm is set up as a latching control, IE; a manual reset is required.

Lo Vacuum Switch

In the event of a low vacuum condition in the LOPRO trays, the low vacuum switch will activate, sending a signal to the GECM Panel. The LOPRO blower (and WTDP) will shut down but the transfer pump will continue to operate until all floats return to the bottom of their travel, emptying the sump. The LCD Screen on the GECM panel will indicate a “LO VACUUM” alarm condition and the Red Blower Fault Light will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Auxiliary (Aux) Shutdown Alarm

An Auxiliary Shutdown Alarm can be connected to integrate with other site specific systems. This is a normally closed switch and will open upon alarm. All running devices will shut down. The LCD screen on the GECM will indicate an AUX SHUTDOWN alarm condition and both Red Fault Lights will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Hi Pressure Switch

In the event of a high-pressure condition in the transfer pump discharge line, the high pressure switch will activate, sending a signal to the GECM. Both the LOPRO blower and transfer pump will shut down. The LCD Screen on the GECM will indicate a “XFER HI PRESS” alarm condition and the Red Transfer Fault Light will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Telemetry

For all of the above alarm conditions, each GECM may be equipped with SMS Telemetry packages that will send alarm-specific text messages to specified phone numbers over a cellular network.

Notes

- The blower and transfer pump are controlled by HOA switches. Each HOA switch is labeled to show which device it controls. HOA switches must be in the AUTO position for the devices to run autonomously. At any time, if a switch is placed in the HAND position, power will be applied to the respective device. If system is in an alarm condition, the HOA switch must be in the OFF position and the RESET button must be pressed in order to allow HAND operation.
- Depending on manufacturer’s specifications, only some blowers and transfer pumps have wiring hook up for thermal overload conditions. When the device is equipped with thermal overload protection from the manufacturer, Geotech will incorporate these inputs into the GECM logic and operation. Please note all motor starters inside the GECM are equipped with thermal overload protection.
- A Dry Contact relay assembly is incorporated into the GECM panel. Upon any of the above mentioned alarm conditions, the Dry Contact will change state sending an output signal (normally closed to open, or normally open to closed) to any customer supplied system interface.

Low Profile (LOPRO) Air Stripper with Influent Water Table Depression Pump (WTDP) GECM Logic Statement

System Overview

A Geotech Low Profile Air Stripper (LOPRO II or III) system consists of a vacuum pump/blower, inlet and outlet plumbing with vacuum gauges and corresponding switches, multiple aeration trays with integral gaskets and latches, a sump, a lid (cover) with mist eliminator. A WTDP pumps water into the system and is operated by the WTDP Probe provided with the system. Effluent water is gravity fed out of the LOPRO Sump. The Geotech Environmental Control Module (GECM) provides automated control for the LOPRO's devices and switches.

GECM Control Panel Components

- (2) Hand/Off/Auto switches (1 for Blower, 1 for WTDP)
- (2) Motor Starters with thermal overload protection (1 for Blower, 1 for WTDP)
- Thermal overload motor coil protection (when applicable)
- Reset Button
- 4-button Keypad
- Dry Contact

GECM Control Indicator Components

- 16 X 2 character LCD Screen
- (2) Green Run Lights (1 for Blower, 1 for WTDP)
- (2) Red Fault Light (1 for Blower, 1 for WTDP)

System Operation

Abbreviations used:

HI = High
LO = Low
BLWR = Blower
XFER = Transfer
OL = Overload

WTDP Probe

The WTDP pump is controlled by the Water Hi/Lo switches actuated by the WTDP probe Hi/Lo float and the Override float. The water pump turns on when the Hi/Lo float rises to the top of its travel. The pump continues to run until the Hi/Lo float falls to the bottom of its travel.

If a probe fault causes the pump to continue running, the Override float will fall and turn off the pump. The GECM will display a "WATER OVERRIDE" alarm condition.

If the Hi switch closes, but the Lo switch remain open, the GECM will display "PROBE FAULT"
Both faults are set up as a latching control, IE; a manual reset is required.

Water Hi-Hi Alarm

If both floats on the sump probe rise to the top of their travel, a Hi-Hi switch will actuate. The Blower and WTDP will shut down. The LCD screen on the GECEM will indicate a "WATER HI-HI" alarm condition and both Red Fault Lights will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Figure A-2: Alarm Conditions




Figure A-2: Alarm Conditions for LOPRO with Influent WTDP

Probe Fault Alarm


A Probe Fault Alarm condition can occur in the WTDP Probe when:

- There is non-sequential movement of the floats and switches
- The probe is installed to the GECEM incorrectly
- There's a break in the wiring
- There's a break in the probe itself

The Probe Fault alarm condition will shut down the **entire** system. The LCD screen on the GECEM will indicate a "PROBE FAULT" alarm condition and both Red Fault Lights will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Tankfull Alarm

A second probe may be used to shut off the appropriate devices for the system when the customer supplied recovery and/or holding tank becomes full. This tankfull probe is a single float activated level sensor installed in the top of the recovery and/or holding tank. When the float rises to the top of its travel. The LOPRO blower and WTDP will shut down. The LCD screen on the GECEM will indicate a "TANKFULL" alarm condition and both Red Fault Lights will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.



When the float rises to the top of travel:
TANKFULL alarm condition

Figure A-3: Tankfull probe alarm condition

Hi Vacuum Switch

In the event of a high vacuum condition in the LOPRO trays, the high vacuum switch will activate sending a signal to the GECM. The LOPRO Blower and WTDP will shut. The LCD screen on the GECM will indicate a “HI VACUUM” alarm condition and the Red Blower Fault Light will illuminate. This alarm is set up as a latching control, IE; a manual reset is required.

Lo Vacuum Switch

In the event of a low vacuum condition in the LOPRO trays, the low vacuum switch will activate, sending a signal to the GECM Panel. The LOPRO Blower and WTDP will shut down. The LCD Screen on the GECM panel will indicate a “LO VACUUM” alarm condition and the Red Blower Fault Light will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Auxiliary (Aux) Shutdown Alarm

An Auxiliary Shutdown Alarm can be connected to integrate with other site specific systems. This is a normally closed switch and will open upon alarm. All running devices will shut down. The LCD screen on the GECM will indicate an AUX SHUTDOWN alarm condition and all Red Fault Lights will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Telemetry

For all of the above alarm conditions, each GECM may be equipped with SMS Telemetry packages that will send alarm-specific text messages to specified phone numbers over a cellular network.

Notes

- The blower, and WTDP are controlled by HOA switches. Each HOA switch is labeled to show which device it controls. HOA switches must be in the AUTO position for the devices to run autonomously. At any time, if a switch is placed in the HAND position, power will be applied to the respective device. If system is in an alarm condition, the HOA switch must be in the OFF position and the RESET button must be pressed in order to allow HAND operation.
- Depending on manufacturer's specifications, only some blowers and transfer pumps have wiring hook up for thermal overload conditions. When the device is equipped with thermal overload protection from the manufacturer, Geotech will incorporate these inputs into the GECM logic and operation. Please note all motor starters inside the GECM are equipped with thermal overload protection.
- A Dry Contact relay assembly is incorporated into the GECM panel. Upon any of the above mentioned alarm conditions, the Dry Contact will change state sending an output signal (normally closed to open, or normally open to closed) to any customer supplied system interface.

Low Profile (LOPRO) Air Stripper with Effluent Transfer Pump and Influent Water Table Depression Pump (WTDP) GECM Logic Statement

System Overview

A Geotech Low Profile Air Stripper (LOPRO II or III) system consists of a vacuum pump/blower, inlet and outlet plumbing with vacuum gauges and corresponding switches, multiple aeration trays with integral gaskets and latches, a sump, a lid (cover) with mist eliminator. A Transfer Pump pumps effluent fluid from the Sump according to the Sump Probe. A WTDP pumps water into the system and is operated by the WTDP Probe provided with the system. The Geotech Environmental Control Module (GECM) provides automated control for the LOPRO's devices and switches.

GECM Control Panel Components

- (3) Hand/Off/Auto switches (1 for Blower, 1 for Transfer Pump, 1 for WTDP)
- (3) Motor Starters with thermal overload protection (1 for Blower, 1 for Transfer Pump, 1 for WTDP)
- Thermal overload motor coil protection (when applicable)
- Reset Button
- 4-button Keypad
- Dry Contact

GECM Control Indicator Components

- 16 X 2 character LCD Screen
- (3) Green Run Lights (1 for Blower, 1 for Transfer Pump, 1 for WTDP)
- (3) Red Fault Light (1 for Blower, 1 for Transfer Pump, 1 for WTDP)

System Operation

Abbreviations used:

HI = High
LO = Low
BLWR = Blower
XFER = Transfer
OL = Overload

Sump Probe

The LOPRO Sump Probe is equipped with two floats that rise and fall with the water level in the sump. The bottom float controls operation of the transfer pump by actuating HI and LO switches on the probe shaft. The pump starts when the float rises to the HI switch and continues to run until the water level drops the float to the LO switch.

WTDP Probe

The WTDP pump is controlled by the Water Hi/Lo switches actuated by the WTDP probe Hi/Lo float and the Override float. The water pump turns on when the Hi/Lo float rises to the top of its travel. The pump continues to run until the Hi/Lo float falls to the bottom of its travel.

If a probe fault causes the pump to continue running, the Override float will fall and turn off the pump. The GECM will display a "WATER OVERRIDE" alarm condition.

If the Hi switch closes, but the Lo switch remain open, the GECM will display "PROBE FAULT"
Both faults are set up as a latching control, IE; a manual reset is required.

Water Hi-Hi Alarm

If both floats on the sump probe rise to the top of their travel, a Hi-Hi switch will actuate. The Blower and WTDP will shut down but the transfer pump will continue to operate until all floats reach the bottom of their travel, emptying the sump. The LCD screen on the GECM will indicate a "WATER HI-HI" alarm condition and the Red Transfer Fault Light will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required (see figure A-2).

Probe Fault Alarm

A Probe Fault Alarm condition can occur in either the WTDP Probe or Sump Probe when:

- There is non-sequential movement of the floats and switches
- The probe is installed to the GECM incorrectly
- There's a break in the wiring
- There's a break in the probe itself

The Probe Fault alarm condition will shut down the **entire** system. The LCD screen on the GECM will indicate a "PROBE FAULT" alarm condition and all Red Fault Lights will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Tankfull Alarm

A second probe may be used to shut off the appropriate devices for the system when the customer supplied recovery and/or holding tank becomes full. This tankfull probe is a single float activated level sensor installed in the top of the recovery and/or holding tank. When the float rises to the top of its travel. The LOPRO blower and transfer pump, and WTDP will all shut down. The LCD screen on the GECM will indicate a "TANKFULL" alarm condition and all Red Fault Lights will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required (see Figure A-3).

Hi Vacuum Switch

In the event of a high vacuum condition in the LOPRO trays, the high vacuum switch will activate sending a signal to the GECM. The LOPRO Blower and WTDP will shut down but the transfer pump will continue to operate until the floats return to the bottom of their travel emptying the sump. The LCD screen on the GECM will indicate a "HI VACUUM" alarm condition and the Red Blower Fault Light will illuminate. This alarm is set up as a latching control, IE; a manual reset is required.

Lo Vacuum Switch

In the event of a low vacuum condition in the LOPRO trays, the low vacuum switch will activate, sending a signal to the GECM Panel. The LOPRO Blower and WTDP will shut down but the transfer pump will continue to operate until all floats return to the bottom of their travel, emptying the sump. The LCD Screen on the GECM panel will indicate a "LO VACUUM" alarm condition and the Red Blower Fault Light will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Auxiliary (Aux) Shutdown Alarm

An Auxiliary Shutdown Alarm can be connected to integrate with other site specific systems. This is a normally closed switch and will open upon alarm. All running devices will shut down. The LCD screen on the GECM will indicate an AUX SHUTDOWN alarm condition and all Red Fault Lights will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Hi Pressure Switch

In the event of a high pressure condition in the transfer pump discharge line, the high pressure switch will activate, sending a signal to the GECM. The LOPRO Blower, WTDP and Transfer Pump will all shut down. The LCD Screen on the GECM will indicate a "XFER HI PRESS" alarm condition and the Red Transfer Fault Light will illuminate. This alarm condition is set up as a latching control, IE; a manual reset is required.

Telemetry

For all of the above alarm conditions, each GECM may be equipped with SMS Telemetry packages that will send alarm-specific text messages to specified phone numbers over a cellular network.

Notes

- The blower, WTDP and transfer pump are controlled by HOA switches. Each HOA switch is labeled to show which device it controls. HOA switches must be in the AUTO position for the devices to run autonomously. At any time, if a switch is placed in the HAND position, power will be applied to the respective device. If system is in an alarm condition, the HOA switch must be in the OFF position and the RESET button must be pressed in order to allow HAND operation.
- Depending on manufacturer's specifications, only some blowers and transfer pumps have wiring hook up for thermal overload conditions. When the device is equipped with thermal overload protection from the manufacturer, Geotech will incorporate these inputs into the GECM logic and operation. Please note all motor starters inside the GECM are equipped with thermal overload protection.
- A Dry Contact relay assembly is incorporated into the GECM panel. Upon any of the above mentioned alarm conditions, the Dry Contact will change state sending an output signal (normally closed to open, or normally open to closed) to any customer supplied system interface.

Appendix B – GECM Installation

Inspection

Inspect all components for physical damage. Installing and operating damaged equipment is dangerous and should not be performed. Verify that all components have arrived as per the Sales Order or packing list.

GECM Installation

Even though the GECM electronics are enclosed within a NEMA 4 rated weatherproof box, it is advised that you place your GECM within a sheltered area, protecting the unit from direct exposure to water and sunlight.

Input Power Guidelines

All wiring must be carried out by a qualified electrician and be in accordance with state and local codes. Conduit runs must conform to current U.S. National Electrical Code (NEC). Do not run any power wires within 2 inches (5 cm) of intrinsically safe (IS) wires or terminals (NEC Article 508 for relevant codes.) All equipment and controls are to be installed in accordance with Article 430 and 504 of the NEC.

See also the GECM Field Wiring Diagram for specific connections to the back panel and Printed Circuit Board (PCB). Geotech provides a detailed Field Wiring Diagram with every GECM built. Copies of these diagrams can be obtained from Geotech when needed.

Access Ports and Conduit Hubs

To facilitate wiring, Geotech installs access ports and conduit hubs to the GECM enclosures that are hard mounted to the system being manufactured, i.e., a LOPRO or SVE. A GECM enclosure will not have this wiring option when built and shipped separately.

When installing a GECM enclosure ensure that ports installed for IS wiring are placed within the upper sides of the enclosure (close to the PCB) and that all conduit hubs for main power, blowers, and pumps are installed along the bottom. To maintain the NEMA 4 weatherproof characteristics of your panel use weatherproof conduit hubs.

Install Chassis Ground

Before beginning the panel hookup procedures, run a wire from the bottom ground lug on the GECM back panel to a good earth ground, i.e., the circuit breaker panel enclosure.

Install IS Ground

Connect IS ground wires to the upper ground lug on the GECM back panel.

Wire Main Power

The GECM is built to run with single phase 115VAC or 230VAC. Incoming power leads are normally connected to either a terminal strip or fused disconnect labeled HOT and NEUTRAL (for 115VAC) or L1, L2 and L3 (for 230VAC and/or three phase applications). When a fused disconnect is installed for 3-Phase power to the motor starters, Geotech will complete all wiring on the GECM side of the components.

The following wiring descriptions are for standard GECM configurations. In conjunction with the GECM Field Wiring Diagram, always refer to the system diagrams and labels found within the device User Manuals, including those diagrams provided with custom built panels.

Install Incoming Power to Motor Starters

Most motor driven devices controlled by the GECM (LOPRO, SVE, Sparge, WTDP, Transfer Pump) require the use of a motor starter. Motor starters are installed to the back panel when the GECM is built. Run main power for the individual motor starters through the bottom of the enclosure. Each motor starter is labeled for the device they support. Single phase power leads are wired to terminals L1 and L2. Three phase power leads are attached to terminals L1, L2, and L3. Attach all ground wires to the ground lug at the bottom of the panel.



DO NOT run power wires within two inches of IS wiring or terminals.

Installing Blower Thermals

The GECM incorporates thermal overload protection for those motors which have it. When a motor manufacturer provides thermal overload protection there will typically be two additional wires within the motor's electrical box labeled "J". These wires will run through the same port used for the motor power and are connected to a terminal strip labeled THERMALS.

Installing an 115VAC/230VAC to 12VDC Power Supply

Power requirements and control are dependent upon the GECM and are probe activated.

The GECM back panel will contain labeled relays or terminal strips (labeled PRODUCT PUMP) from which hot leads will be connected. These leads will then go to a designated power supply box and be converted to 12VDC for product pump operation.



Power supply boxes should be installed as near to the well as possible to reduce DC line loss in the cable connecting the product pump to the box.

Use the GECM Field Wiring Diagram to complete all wire connections between the GECM and the power supply box.

IS Wiring Installation Guidelines

The GECM incorporates circuitry for IS circuit extensions into hazardous locations. All IS wiring must be at least 2" (5cm) from all other non-IS wiring. All IS wire terminations must be securely tightened in screw terminals on the GECM PCB.

It is recommended that you use only Geotech supplied probe cable (P/N ORS418005) for IS wiring and Geotech supplied IS float probes with jacketed cable. The maximum length of a Geotech probe cable that can be connected to IS circuitry is 500 ft. (152 m).

Wiring Reservoir, Tankfull, Sump and Water Pump Probes

These devices are wired to designated ports on the GECM PCB and are defined on the GECM Field Wiring Diagram provided. Wiring diagrams for the various equipment probes and devices can be found within the user manuals for the device they support. Common probes built by Geotech support the operation of the following devices:

Sump Probe

LOPRO II and III Air Strippers

Using a MeLabs Field Programmer

If for any reason the GECM needs to undergo a firmware update, Geotech will provide the new software on a MeLabs Field Programmer. Follow the instructions below to successfully update the GECM.

1. Verify SD card is properly inserted into card slot. Press the back of the SD card to ensure it is inserted as far as it will go. There will be a click to release or lock the card in.
 - Do this a couple time to verify the card is in proper position. A small portion of the card will stick out from the end of the programmer housing.
2. Open GECM door and inner panel to gain access to controller board.
3. Remove the PCB Enclosure using a 5/16" wrench/nut driver or #2 Philips screwdriver.
4. At the top near the middle will be a 6 pin jack
 - Black phone jack like housing.
5. Plug the cable of field programmer into the jack.
6. With power applied to the unit the LED will be lit up GREEN.
7. Press the program button on the face of the field programmer.
8. During programming LED will be a solid RED.
 - If LED Flashes RED call Geotech at 1-800-833-7958 or 303-320-4764.
9. When programming is completed the LED will return to a solid GREEN.
10. Remove cable from controller board, reinstall the PCB enclosure and close up the GECM.

Unit is now ready for use.

Appendix C – Decontamination Procedures

Some common decontamination solutions are listed below along with the contaminants they are effective against.

<u>Solution</u>	<u>Effective Against</u>
Water	Short-chain hydrocarbons, inorganic compounds, salts, some organic acids, other polar compounds.
Dilute Acids	Basic (caustic or alkaline) compounds, amines, hydrazines.
Dilute Bases	Acidic compounds, phenols thiols, some nitro- and sulfonic compounds.
Organic solvents	Non-polar compounds (such as some organic compounds)

The use of organic solvents is not recommended because:

- 1) Organic solvents can permeate and/or degrade protective clothing
- 2) They are generally toxic and may result in unnecessary employee exposure to hazardous chemicals.

Dish washing liquid detergents are a great alternative. As a decontamination solution, it is readily available, is the safest of all the above, and is usually strong enough if used generously.

The use of steam can also be effective for decontamination. A water-laser (pressurized water) is exceptionally valuable.

The following substances are noted for their particular efficiency in removing certain contaminants or for decontaminating certain types of equipment.

<u>Solution</u>	<u>Effective Against</u>
Penetone	PCB Contamination <i>*Penetone may also remove paint, it is a good idea to spot-test before use</i>
Phosphate free detergent	Contaminated pumps
Ivory liquid	Oils
Diluted HTH	Cyanides
Radiac	Low level radioactivity
Isopropanol	Biological agents <i>*DO NOT use on rubber products since it will break down rubber</i>
Hexane	Certain types of lab or sampling equipment <i>*Use of hexane is discouraged due to its flammability and toxicity</i>
Zep	General purpose cleaning
Phosphate free detergent	General purpose cleaning

Decontamination Solutions to Avoid

Some decontamination solutions should be avoided because of their toxicity, flammability, or harmful effects to the environment. Halogenated hydrocarbons, such as carbon tetrachloride, should not be used because of their toxicity, possible incompatibility, and some because of their flammability.

Organic decontamination solutions should not be used on personal protective equipment (PPE) because they may degrade the rubber or other materials comprising the PPE.

Mercurials are sometimes used for sterilization. They should be avoided because of their toxicity.

Chemical leaching, polymerization, and halogen stripping should all be avoided because of possible complications during decontamination.

Sand-blasting, a method of physical removal, should be avoided because the sand used on the contaminated object usually needs to be disposed of as hazardous waste, a very costly proposition. In addition, sand-blasting exposes personnel to silica, a carcinogen.

Freon is known to be particularly effective for the cleansing of PCB's but its effect on the ozone layer is extremely harmful. Its use is discouraged.

Strong acids or bases should not be used when cleaning metals and gaskets or tools or other equipment because of the possibility of corrosion.

Disposal of Decontamination Solutions and Waste Water

All solutions and water used for decontamination must be collected. If lab analysis indicates that the water and/or solutions exceed allowable contamination levels, they must be treated as hazardous waste. Alternatively, the solutions and water may be treated on-site to lower the contamination levels and render them non-hazardous.

Containers such as 55 gallon (208 L) drums should be available for storage of wastes.

Spent decontamination solutions can be collected by using heavy-duty plastic sheets, visqueen sheets, kiddie pools, or if needed, a larger containment basin. The decontamination of equipment must be performed on the sheets or in the basins. They could be placed on a slight angle so that the spent decontamination solutions drain into a collection basin or drum.

Recommended Supplies for Decontamination of Personnel, Clothing and Equipment

The list below contains recommendations for supplies which would be on hand for the decontamination of personnel, clothing and equipment. Depending on the site activities, not all of these items may be needed. Alternatively, some additional items not listed here may be required.

- Drop cloths of plastic or other suitable material, such as visqueen, for heavily contaminated equipment.
- Disposal collection containers, such as drums or suitably lined trash cans for disposable clothing and heavily contaminated personal protective clothing or equipment to be discarded.

- Lined box with adsorbent for wiping or rinsing off gross contaminants and liquid contaminants.
- Wash tubs of sufficient size to enable workers to place booted foot in and wash off contaminants (without a drain or with a drain connected to a collection tank or appropriate treatment system).
- Rinse tubs of sufficient size to enable workers to place booted foot in and wash off contaminants (without a drain or with a drain connected to a collection tank or appropriate treatment system).
- Wash solutions selected to wash off and reduce the hazards associated with the contaminated wash and rinse solutions.
- Rinse solution (usually water) to remove contaminants and contaminated wash solutions.
- Long-handled, soft-bristled brushes to help wash and rinse off contaminants.
- Lockers and cabinets for storage of decontaminated clothing and equipment.
- Storage containers for contaminated wash and rinse solutions.
- Plastic sheeting, sealed pads with drains, or other appropriate method for containing and collecting contaminated wash and rinse water spilled during decontamination.
- Shower facilities for full body wash or at a minimum, personal wash sinks (with drains connected to a collection tank or appropriate treatment system).
- Soap or wash solution, wash cloths and towels.
- Clean clothing and personal item storage lockers and/or closets.

NOTES

NOTES

DOCUMENT REVISIONS		
EDCF#	DESCRIPTION	REV/DATE
-	Previous Release	01/09/2013
Project 1409	Edited images and spare parts to show new style shroud, edited tubing from poly to FEP, SP	10/30/2014
Project #1553	Added GECM to user manual, updates to price page, and other minor edits – StellaR	12/18/2018

The Warranty

For a period of one (1) year from date of first sale, product is warranted to be free from defects in materials and workmanship. Geotech agrees to repair or replace, at Geotech's option, the portion proving defective, or at our option to refund the purchase price thereof. Geotech will have no warranty obligation if the product is subjected to abnormal operating conditions, accident, abuse, misuse, unauthorized modification, alteration, repair, or replacement of wear parts. User assumes all other risk, if any, including the risk of injury, loss, or damage, direct or consequential, arising out of the use, misuse, or inability to use this product. User agrees to use, maintain and install product in accordance with recommendations and instructions. User is responsible for transportation charges connected to the repair or replacement of product under this warranty.

Equipment Return Policy

A Return Material Authorization number (RMA #) is required prior to return of any equipment to our facilities, please call our 800 number for appropriate location. An RMA # will be issued upon receipt of your request to return equipment, which should include reasons for the return. Your return shipment to us must have this RMA # clearly marked on the outside of the package. Proof of date of purchase is required for processing of all warranty requests.

This policy applies to both equipment sales and repair orders.

FOR A RETURN MATERIAL AUTHORIZATION,
PLEASE CALL OUR SERVICE DEPARTMENT AT 1-800-833-7958

Model Number: _____

Serial Number: _____

Date of Purchase: _____

Equipment Decontamination

Prior to return, all equipment must be thoroughly cleaned and decontaminated. Please make note on RMA form, the use of equipment, contaminants equipment was exposed to, and decontamination solutions/methods used.

Geotech reserves the right to refuse any equipment not properly decontaminated. Geotech may also choose to decontaminate equipment for a fee, which will be applied to the repair order invoice.

Geotech Environmental Equipment, Inc
2650 East 40th Avenue Denver, Colorado 80205
(303) 320-4764 • **(800) 833-7958** • FAX (303) 322-7242
email: sales@geotechenv.com website: www.geotechenv.com